

Temora Sewage Treatment Plant

EPA Licence Number 2523



TEMORA
The Friendly Shire

Temora Shire Council
Temora Sewage Treatment Plant
Teal Street
TEMORA NSW 2666

Location of Monitoring Point 5: Sewage Treatment Pond 6 - discharge to utilisation area

Monitoring Frequency required by licence: monthly

Date sample taken: 26.03.2024
Date sample sent to laboratory: 26.03.2024
Date data received from laboratory: 26.04.2024
Date data published: 30.04.2024
Date published within 14 days: Yes

Summary of Results for: March 2024

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	8	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	3	No
Oil & Grease	mg/L	20	1	No
pH	pH units	5.5 - 9.5	8.8	No
Total Suspended Solids	mg/L	40	10	No
Ammonia as N	mg/L	-	0.4	No
Conductivity	µS/cm	-	918	No
Nitrate/Nitrite as N	mg/L	-	0.6	No
Nitrogen, total	mg/L	-	4	No
Total Kjeldahl Nitrogen	mg/L	-	3	No
Phosphorous, total	mg/L	-	4.16	No

Temora Sewage Treatment Plant

EPA Licence Number 2523



TEMORA
The Friendly Shire

Temora Shire Council
Temora Sewage Treatment Plant
Teal Street
TEMORA NSW 2666

Location of Monitoring Point 5: Sewage Treatment Pond 6 - discharge to utilisation area

Monitoring Frequency required by licence: monthly

Date sample taken: 30/4/24

Date sample sent to laboratory: 30/4/24

Date data received from laboratory: 7/6/24

Date data published: 13/6/24

Date published within 14 days: Yes

Summary of Results for: April 2024

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	6	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	20	No
Oil & Grease	mg/L	20	<1	No
pH	pH units	5.5 - 9.5	8.2	No
Total Suspended Solids	mg/L	40	9	No
Ammonia as N	mg/L	-	0.6	No
Conductivity	µS/cm	-	918	No
Nitrate/Nitrite as N	mg/L	-	0.5	No
Nitrogen, total	mg/L	-	4	No
Total Kjeldahl Nitrogen	mg/L	-	3	No
Phosphorous, total	mg/L	-	4.03	No

Temora Sewage Treatment Plant

EPA Licence Number 2523



TEMORA
The Friendly Shire

Temora Shire Council
Temora Sewage Treatment Plant
Teal Street
TEMORA NSW 2666

Location of Monitoring Point 5: Sewage Treatment Pond 6 - discharge to utilisation area

Monitoring Frequency required by licence: monthly

Date sample taken: 26/5/24

Date sample sent to laboratory: 24/5/24

Date data received from laboratory: 24/6/24

Date data published: 25/6/24

Date published within 14 days: Yes

Summary of Results for: April 2024

Pollutant	Unit of Measure	Limit	Test Result	Limit Exceeded
Biochemical Oxygen Demand	mg/L	30	3	No
Faecal Coliforms	per 100mL	200 (80%) 600 (100%)	222	No
Oil & Grease	mg/L	20	3	No
pH	pH units	5.5 - 9.5	8.4	No
Total Suspended Solids	mg/L	40	13	No
Ammonia as N	mg/L	-	0.4	No
Conductivity	µS/cm	-	880	No
Nitrate/Nitrite as N	mg/L	-	0.9	No
Nitrogen, total	mg/L	-	4	No

Total Kjeldahl Nitrogen	mg/L	-	3	No
Phosphorous, total	mg/L	-	4.68	No